

## COLORADO RENU LOAN ELIGIBLE MEASURES

Measure	Minimum Efficiency Requirement
Air sealing	Pre- and post-installation blower door test
Air-source heat pump	Ducted: ≥ 7.8 HSPF2 / ≥ 15.2 SEER2 / ≥ 11.7 EER2 for split systems  Ductless: ≥ 7.8 HSPF2 / ≥ 15.2 SEER2
Battery storage	Must meet local utility requirements
Central Air Conditioning	≥ 15.2 SEER2 / ≥ 12 EER2
Doors	Opaque: U-Factor ≤ 0.17, SHGC no rating ≤ 1/2-Lite: U-Factor ≤ 0.25, SHGC ≤ 0.25 > 1/2-Lite: U- Factor ≤ 0.30, SHGC ≤ 0.40
Electrical panel upgrade	Must accompany the installation of a qualifying energy upgrade (e.g. solar PV system, heat pump, etc.)
EV charging station	Level 2
Evaporative cooling	≥ 2500 CFM
Furnace	≥ 95% AFUE
Geothermal system (water-to-air, closed loop)	≥ 17.1 EER, ≥ 3.6 COP
Geothermal system (water-to-air, open loop)	≥ 21.1 EER, ≥ 4.1 COP
Geothermal system (water-to- water, closed loop)	≥ 16.1 EER, ≥ 3.1 COP
Geothermal system (water-to- water, open loop)	≥ 20.1 EER, ≥ 3.5 COP

Measure	Minimum Efficiency Requirement
Insulation - attic/ceiling	Climate zone 3: R-49 minimum Climate zones 4-7: R-60 minimum Pre- and post-installation blower door test
Insulation - floor	Climate zones 3-4: R-19 minimum Climate zones 5-6: R-30 minimum Climate zone 7: R-38 minimum Pre- and post-installation blower door test
Insulation - wall	R-19 minimum; fill wall cavity where R-value is not possible Pre- and post-installation blower door test
Solar PV	
Water heater (electric heat pump)	UEF ≥ 3.30
Water heater (electric)	UEF ≥ 0.93
Water heater (gas storage)	UEF ≥ 0.86
Water heater (gas tankless)	UEF ≥ 0.95
Windows	U-Factor ≤ 0.27, SHGC any U-Factor = 0.28, SHGC ≥ 0.32 U-Factor = 0.29, SHGC ≥ 0.37 U-Factor = 0.30, SHGC ≥ 0.42