



**ELECTRIFY AND SAVE™**  
**ELIGIBLE MEASURES**

<b>Measure</b>	<b>Minimum Efficiency Requirement</b>
<b>Air Sealing</b>	n/a
<b>Battery Storage</b>	Must be enrolled in DRC program with TS
<b>Electrical Panel Upgrades</b>	Must be part of qualifying space conditioning project
<b>Electric Thermal Storage</b>	Units must be controlled by timers or a master control system
<b>Electrical Vehicle (EV) Charging</b>	n/a
<b>Lighting</b>	LED
<b>Insulation – Attic/Ceiling</b>	Climate zone 3: R-49 minimum Climate zones 4-7: R-60 minimum
<b>Insulation – Floor/Crawl Space</b>	Floor over conditioned space Climate zones 3-4: R-19 minimum Climate zones 5-6: R-30 minimum Climate zone 7: R-38 minimum Crawl Space Climate zones 3-4: R-13 minimum Climate zones 5-7: R-19 minimum
<b>Insulation – Wall</b>	R-19 minimum; fill wall cavity where R-value is not possible

Measure	Minimum Efficiency Requirement
<b>Smart Thermostat</b>	Must be on time of use rate or managed platform
<b>Space Conditioning, Ground Source Heat Pump (GSHP), Fans, Evaporative Coolers</b>	Water-to-air, close loop: $\geq 17.1$ EER, $\geq 3.6$ COP Water-to-air, open loop: $\geq 21.1$ EER, $\geq 4.1$ COP Water-to-water, closed loop: $\geq 16.1$ EER, $\geq 3.1$ COP Water-to-water, open loop: $\geq 20.1$ EER, $3.5$ COP Evaporative Cooler $\geq 2500$ CFM
<b>Space Conditioning – Air Source Heat Pump (ASHP)</b>	Ducted HSPF2 $\geq 7.8$ Ductless HSPF2 $\geq 8.5$ Dual fuel systems must be $\geq 90\%$ efficient
<b>Water Heating</b>	UEF > 3.3
<b>Windows and Doors</b>	ENERGY STAR®*; no historic window replacement; historic windows may be repaired with prior approval *exceptions will be made for single pane window replacements: new windows must adhere to the most recent IECC requirements

8 | gWcgi fY.  
 V@ Áñ óñ &| • ã^ Áñ^ óñ [ óñ @ë • ã^ Áñ^ Óë & @ñ [ b & ñ Áñ çã, ^ áñ áñ ãñ ãñ ãñ Áñ Áñ } • ^ Áñ { ] / ^ @ } • ã^ Áñ [ } • ãñ / ãñ } Áñ ãñ áñ | ãñ ãñ ãñ ãñ [ ãñ ^ Áñ [ [ ãñ \* Áñ | Áñ ^ & ãñ Áñ ^ ãñ ^ Áñ [ óñ ç ãñ @ / ^ Áñ | ãñ ^ Áñ [ ãñ & ãñ Óñ Óñ Áñ | Áñ • ãñ ãñ & ãñ